

Bangiya Gramin Vikash Bank
North 24 Parganas Regional Office
371/A/1 Shalbagan Barrackpore Road
Barasat, Kolkata-700125

Invitation for tender offer for Electrical work inclusive of DB's, cabling and wiring

Bangiya Gramin Vikash Bank, North 24 Parganas Regional Office invites sealed tenders from licensed contractors for executions of various type of data wiring work inclusive of DB's, cabling and wiring of our following proposed branches

1. Kalitala- Vill+ PO- Kalitala, Block-Hingalganj, North 24 Parganas
2. Monipur- Vill+PO- Monipur, Block- Sandeshkhali II, North 24 Parganas.
3. Jeliakhali (Paschim)- Vill+PO- Jeliakhali, Block- Sandeshkhali II, North 24 parganas.

The work Schedule may be Downloaded from www.bgyb.co.in .

Last Date and Time for receipts of tender offers 11.09.2014.at 14.00 Hrs.

Date of Opening of Technical Bid 12.09.2014 at 10.00 Hrs.

Date of opening of Commercial Bid 12.09.2014 10.00 Hrs

(Authorised representatives may be present at the time of opening of the tender.)
Commercial and Technical Bids should be submitted separately in sealed covers.
Bank Reserves the right to cancel any bid without showing any reason thereof

c

Sl No	Particulars	Unit	Estimated Rate
1	Computer Power Board Mail Line Supply of new computer power wiring 1x3 nos.1,5 sq mm (copper wire) separate phase neutral and earthing with 20 mm.PVC(ISI) stick pipe and 20mm PVC saddle and 25mm flexible pipe with PVC gland circuit B/B to connect power board mainline wiring complete fittings and fixing etc (Make-Finolex/Havells)	Per meter	
2	UPS input-Output Main Line- Supply of new 1X2 nos.6 sq.mm (Copper wire) separate phase neutral and1X1 nos 4 sq.mm. earthing with 20mm PVC (ISI) stick pipe and 20mmPVC saddle and 25 mm flexible pipe with gland UPS output input main line wiring complete fitting and fixing etc (Make- Finolex/Havelles)	Per meter	
3	Computer Power Switch Board Supply of new 8/10 inch galvanised (GI) board and 9/11 inch 4 mm fibre top with 6 amp,5 pin socket 4 nos, with 6 amp single way switch 4 nos, 10 amps integrated lamp 1 no, 10 amp Board fuse 1 no,1 inch size brass screw with washer complete fitting and fitting etc.(Make- Anchor /Pritam Prity for all switch ,plug, integrator board fuse)	1 unit per PC	
4	Computer Circuit DB Supply of new D/B 6 way SPN single pole MCB (Miniature Circuit Breaker) 6 nos complete fitting and fixing etc.(Make-Havells/Siemens)	2 Units per branch	
5	UPS output isolator D/B Supply of new 4 way SPN single door distribution Box with 40 amp. DB incoming isolator 2 nos complete fitting and fixing etc .(Make-Havells/Siemens)	1 unit per branch	
6	UPS Output MCB D/B Supply of new 4 way SPN single door D/B (Distribution Box) with 40 amp DP MCB 2 nos complete fitting and fixing etc .(Make-Havells/Siemens)	1 unit per branch	
7	UPS 1-UPS 2 By pass Changer Supply of new 32 amp 4 pole change over switch from UPS 1 and UPS 2 by pass connection complete fitting and fixing etc .(Make-Havells/Siemens)	1 unit per branch	
8	UPS input D/B Supply of new 2+4 SPN single door D/B (Distribution Box) with 40 amp DP isolator 2 nos,63 amp, incoming isolator 1 no complete fitting anf fixing etc .(Make-Havells/Siemens)	1 unit per branch	
9	CBS Process Earthing Supply of new 300mm X 300mm -3 mm thick copper plate electrode to be installed so that its top graded shall be at a minimum depth of 3 mtr below ground level after portion of ground with charcoal and salt and connecting with ½ inch PVC pipe with 6 mm copper earth lead in upto 10 mtr length by bolting and brazing to the GI bolts and suitable length double nuts and washers including supply and fixing with water arrangements 19 mm PVC pipe after portion 30 cm/30 cm cast iron hanged to iron frame water funnel and concrete manhole chamber complete fitting and fixing etc.	1 unit per branch	

Contd-2

Sl No	Particulars	Unit	Estimated Rate
10	Earth Bar to input: D/B Running Earthing	Per meter	
	Supply of new running earth 4.00 sq mm copper wire with 20 mm PVC stick pipe and 20mm saddle with 25 mm flexible pipe complete fitting and fixing etc (Make –Havells /Finolex)		
11	Branch Head Main Switch_	1 unit per branch	
	Supply of new 63 amp single phase DP power main switch suitable size iron frame and suitable size GI nuts & bolts with washer complete fittings and fixing etc (Make – Havells/Floral/Siemens)		
12	Main Switch to Change Over Main Line	Per meter	
	Supply of new 6 sq mm separate phase and neutral 20 mm PVC stick pipe (ISI) and 20 mm PVC saddle with elbow main switch to change over switch main line surface wiring complete fitting and fixing (Make- Havells /Finolex)		
13	Service Cable-	As per requirement	
	Supply of new 10 sqmm: 2 core PVC non armoured aluminium conductor cable (Make –Havells /Finolex)		
14	CA Output-	1 unit per branch	
	Supply of new 63 amp CA cut out (Make0 Flora)		
15	Full Load Branch Generator and Electric Change Over:	1 unit per branch	
	Supply of new 63 amp, single phase change over switch suitable size iron frame and suitable size GI nuts & bolts with washer complete fittings and fixing etc (Make- Bentek/Flora/Siemens)		

